

REX POWER MAGNETICS

A DIVISION OF TRANSFACTOR INDUSTRIES INC. 65 BASALTIC RD, CONCORD, ON, CA L4K 1G4 TEL: 905-695-8844 FAX: 905-695-8855 WWW.REXPOWERMAGNETICS.COM

Purchaser: TBA TBA PO#: SWO#: TBA

Qtv:

Termination

Secondary:

Wiring Connection:

Primary:

Primary:

Voltage

630

615

600

585

570

208

120

Ø 5/8 MTG. HOLE

Secondary:

Voltage

- 3 Phase Isolation - Dry Type

- ANN Self Cooled

ENERGY EFFICIENT TRANSFORMER

- Suitable for Nonsinusoidal Current Load

TBA

Location

Front

Back

H1-H2-H3

% Tap

105.0

102.5

100.0

97.5

95.0

X0-X1-X2-X3

Phase

3

1

with a K-Factor not to exceed 4

Coils:	Aluminum
Cat. No.:	BA500J-M/K4/T80/Z3
kVA: Primary: Secondary: Primary Taps: -Taps FCAN -Taps FCBN	500 600 Delta Volts 208 Y/120 Volts 2.5 % 2
-тарат СБП	2
Frequency:	60 Hz
BIL:	10 kV
Insulation Class:	220 °C
Temperature Rise:	80 °C
Impedance:	5.0 - 6.0 %
Min.Efficiency: -Calculated @ 35% Load	99.14 % ed
Weight:	4170 Lbs

FRONT VIEW

701/2

SHIELD	55 — 45 — • • • • • • • • • • • • • • • • • •	
\		

SIDE VIEW

Preliminary Drawing ONLY

This drawing may NOT truly reflect our final design. Any resulting order(s) must be accompanied by or refer to this drawing and be marked with any proposed changes

Standards:

Terminals

Links:

1-2

2-3

3-4

4-5

5-6

Connect Loads To:

X1-X2-X3 X0-X1, X0-X2,

and/or X0-X3


Pads

Pads

- 1. CSA Certified
 - File No. LR34493
- 2. UL Listed
 - File No. E108255

Standard Features:

- 1. Anti-vibration pads installed between the enclosure base and the core & coil assembly
- 2. Lug for Earth grounding provided
- 3. Neutral rated 200% of the line terminals
- 4. Seismic rated for USA zone 4 and Canada zone 6
- 5. Transformer meets DOE 2016 efficiency level



CSA Enclosure:

- 1. Type 3R (NEMA 3R)
 - Sprinklerproof when the angle between sprinkler heads and opening in the enclosure does not exceed 45 degree from the vertical.
- 2. Ventilated
- 3. ASA 61 grey
- 4. Floor mounting

Rev.	Remarks	Ву	Appr. By	Date

Date:

Prepared by: AG VS Approved by

NOV.26, 2015