

SCHEMATIC 1T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	600	100.0	n/a
	<b>Secondary volts</b>	<b>Connect Loads to</b>	
	208	X1-X2-X3	
120	X0-X1, X0-X2 and/or X0-X3		

SCHEMATIC 2T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	630	105.0	1-1-1
	600	100.0	2-2-2
	570	95.0	3-3-3
<b>Secondary volts</b>	<b>Connect Loads to</b>		
208	X1-X2-X3		
120	X0-X1, X0-X2 and/or X0-X3		

SCHEMATIC 3T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	630	105.0	1-1-1
	615	102.5	2-2-2
	600	100.0	3-3-3
585	97.5	4-4-4	
570	95.0	5-5-5	
<b>Secondary volts</b>	<b>Connect Loads to</b>		
208	X1-X2-X3		
120	X0-X1, X0-X2 and/or X0-X3		

SCHEMATIC 4T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Links</b>
	630	105.0	1-2
	615	102.5	2-3
	600	100.0	3-4
585	97.5	4-5	
570	95.0	5-6	
<b>Secondary volts</b>	<b>Connect Loads to</b>		
208	X1-X2-X3		
120	X0-X1, X0-X2 and/or X0-X3		

SCHEMATIC 5T	CONNECTIONS												
	<b>Primary: H1-H2-H3</b>												
	<table border="1"> <thead> <tr> <th>Voltage</th> <th>% Tap</th> <th>Connect Lines to</th> </tr> </thead> <tbody> <tr> <td>630</td> <td>105.0</td> <td>1-1-1</td> </tr> <tr> <td>600</td> <td>100.0</td> <td>2-2-2</td> </tr> <tr> <td>570</td> <td>95.0</td> <td>3-3-3</td> </tr> </tbody> </table>	Voltage	% Tap	Connect Lines to	630	105.0	1-1-1	600	100.0	2-2-2	570	95.0	3-3-3
	Voltage	% Tap	Connect Lines to										
	630	105.0	1-1-1										
	600	100.0	2-2-2										
570	95.0	3-3-3											
<table border="1"> <thead> <tr> <th>Secondary volts</th> <th>Connect Loads to</th> </tr> </thead> <tbody> <tr> <td>208</td> <td>X1-X2-X3</td> </tr> </tbody> </table>	Secondary volts	Connect Loads to	208	X1-X2-X3									
Secondary volts	Connect Loads to												
208	X1-X2-X3												

SCHEMATIC 6T	CONNECTIONS																		
	<b>Primary: H1-H2-H3</b>																		
	<table border="1"> <thead> <tr> <th>Voltage</th> <th>% Tap</th> <th>Connect Lines to</th> </tr> </thead> <tbody> <tr> <td>630</td> <td>105.0</td> <td>1-1-1</td> </tr> <tr> <td>615</td> <td>102.5</td> <td>2-2-2</td> </tr> <tr> <td>600</td> <td>100.0</td> <td>3-3-3</td> </tr> <tr> <td>585</td> <td>97.5</td> <td>4-4-4</td> </tr> <tr> <td>570</td> <td>95.0</td> <td>5-5-5</td> </tr> </tbody> </table>	Voltage	% Tap	Connect Lines to	630	105.0	1-1-1	615	102.5	2-2-2	600	100.0	3-3-3	585	97.5	4-4-4	570	95.0	5-5-5
	Voltage	% Tap	Connect Lines to																
	630	105.0	1-1-1																
	615	102.5	2-2-2																
600	100.0	3-3-3																	
585	97.5	4-4-4																	
570	95.0	5-5-5																	
<table border="1"> <thead> <tr> <th>Secondary volts</th> <th>Connect Loads to</th> </tr> </thead> <tbody> <tr> <td>208</td> <td>X1-X2-X3</td> </tr> </tbody> </table>	Secondary volts	Connect Loads to	208	X1-X2-X3															
Secondary volts	Connect Loads to																		
208	X1-X2-X3																		

SCHEMATIC 7T	CONNECTIONS						
	<b>Primary: H1-H2-H3</b>						
	<table border="1"> <thead> <tr> <th>Voltage</th> <th>% Tap</th> <th>Connect Lines to</th> </tr> </thead> <tbody> <tr> <td>600</td> <td>100.0</td> <td>n/a</td> </tr> </tbody> </table>	Voltage	% Tap	Connect Lines to	600	100.0	n/a
	Voltage	% Tap	Connect Lines to				
600	100.0	n/a					
<table border="1"> <thead> <tr> <th>Secondary volts</th> <th>Connect Loads to</th> </tr> </thead> <tbody> <tr> <td>208</td> <td>X1-X2-X3</td> </tr> </tbody> </table>	Secondary volts	Connect Loads to	208	X1-X2-X3			
Secondary volts	Connect Loads to						
208	X1-X2-X3						

SCHEMATIC 8T	CONNECTIONS												
	<b>Primary: H1-H2-H3</b>												
	<table border="1"> <thead> <tr> <th>Voltage</th> <th>% Tap</th> <th>Connect Lines to</th> </tr> </thead> <tbody> <tr> <td>630</td> <td>105.0</td> <td>1-1-1</td> </tr> <tr> <td>600</td> <td>100.0</td> <td>H1-H2-H3</td> </tr> <tr> <td>570</td> <td>95.0</td> <td>2-2-2</td> </tr> </tbody> </table>	Voltage	% Tap	Connect Lines to	630	105.0	1-1-1	600	100.0	H1-H2-H3	570	95.0	2-2-2
	Voltage	% Tap	Connect Lines to										
	630	105.0	1-1-1										
	600	100.0	H1-H2-H3										
570	95.0	2-2-2											
<table border="1"> <thead> <tr> <th>Secondary volts</th> <th>Connect Loads to</th> </tr> </thead> <tbody> <tr> <td>208</td> <td>X1-X2-X3</td> </tr> </tbody> </table>	Secondary volts	Connect Loads to	208	X1-X2-X3									
Secondary volts	Connect Loads to												
208	X1-X2-X3												

SCHEMATIC 9T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	630	105.0	1-1-1
	600	100.0	2-2-2
	570	95.0	3-3-3
	<b>Secondary volts</b>		<b>Connect Loads to</b>
208		X1-X2-X3	

SCHEMATIC 10T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	630	105.0	1-1-1
	615	102.5	2-2-2
	600	100.0	3-3-3
	585	97.5	4-4-4
570	95.0	5-5-5	
<b>Secondary volts</b>		<b>Connect Loads to</b>	
208		X1-X2-X3	

SCHEMATIC 11T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Jumpers to</b>
	630	105.0	1-1-1
	600	100.0	2-2-2
	570	95.0	3-3-3
	<b>Secondary volts</b>		<b>Connect Loads to</b>
240		X1-X2-X3	
120		X1-A or A-X2	

SCHEMATIC 12T	CONNECTIONS		
	<b>Primary: H1-H2-H3</b>		
	<b>Voltage</b>	<b>% Tap</b>	<b>Connect Lines to</b>
	630	105.0	1-1-1
	615	102.5	2-2-2
	600	100.0	3-3-3
	585	97.5	4-4-4
570	95.0	5-5-5	
<b>Secondary volts</b>		<b>Connect Loads to</b>	
240		X1-X2-X3	
120		X1-A or A-X2	